



Type test Certificate of complete type tests

AMSGB

Nilai, Malaysia

has successfully passed the type test sequence on an

Power transformer

Type: DTT HIL 1600/10

Rating: 1600 kVA - 11000 V $\pm 2 \times 2,5\%$ / 0,433 kV - Dyn11 - 50 Hz

The test object passed the specification of test duties of

IEC 60076

The test results are recorded in Certificate No.

TDT 2123-10

This Certificate is issued on 18 August 2010

KEMA Nederland B.V.

P.G.A. Bus
KEMA T&D Testing Services
Managing Director

Copyright © KEMA Nederland B.V.

Please note that this document has been issued for information purposes only, and that the original bound and sealed paper copy of the Certificate including the results of the tests of the apparatus will prevail. This document does not imply that KEMA has certified or approved any apparatus other than the specimen tested.

